CARO ANALYTICAL SERVICES

SAMPLE ANALYTICAL DATA

REPORTED TO	SION Improvement District	**WORK ORDER**	6121743
PROJECT	Drinking Water	**REPORTED**	2016-12-30

Analyte	Result / *Recovery*	Standard / Guideline	MRL / *Limits*	Units	Prepared	Analyzed	Notes
Sample ID: 6140 Community Centre Road (6121743-01) [Water] Sampled: 2016-12-28 11:15							
Microbiological Parameters							
Coliforms, Total	< 1	MAC = None Detected	1	CFU/100 mL	N/A	2016-12-29	
E. coli	< 1	MAC = None Detected	1	CFU/100 mL	N/A	2016-12-29	
Sample ID: 8505 Outlook Rd. (6121743-02) [Water] Sampled: 2016-12-28 11:45							
Microbiological Parameters							
Coliforms, Total	< 1	MAC = None Detected	1	CFU/100 mL	N/A	2016-12-29	
E. coli	< 1	MAC = None Detected	1	CFU/100 mL	N/A	2016-12-29	