SAMPLE ANALYTICAL DATA

REPORTED TO	SION Improvement District	**WORK ORDER**	7010920
PROJECT	Drinking Water	**REPORTED**	2017-01-18

Analyte	Result / *Recovery*	Standard / Guideline	MRL / *Limits*	Units	Prepared	Analyzed	Notes
Sample ID: 6140 Community Centre Road (7010920-01) [Water] Sampled: 2017-01-16 11:30							
Microbiological Parameters							
Coliforms, Total	< 1	MAC = None Detected	1	CFU/100 mL	N/A	2017-01-17	
E. coli	< 1	MAC = None Detected	1	CFU/100 mL	N/A	2017-01-17	
Sample ID: 8505 Outlook Rd. (7010920-02) [Water] Sampled: 2017-01-16 12:00							
Microbiological Parameters							
Coliforms, Total	< 1	MAC = None Detected	1	CFU/100 mL	N/A	2017-01-17	
E. coli	< 1	MAC = None Detected	1	CFU/100 mL	N/A	2017-01-17	