

### ANALYTICAL RESULTS

Sample Site	3185 Ward Rd., Grand Forks, BC			Sample #	1
Date/Time Sampled	2018-08-07	12:00 PM	Matrix	Temperature on Receipt	14

Date/Time on Test 2018-08-08 10:45 AM

<u>Analyses</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Guideline<sup>1</sup></u>
Coliforms, Total	less than 1	CFU/100mL	1	MAC: none detected
Verified E.coli	less than 1	CFU/100mL	1	MAC: none detected

Sample Site	4515 Canning Rd., Grand Forks, BC			Sample #	2
Date/Time Sampled	2018-08-07	12:00 PM	Matrix	Temperature on Receipt	14

Date/Time on Test 2018-08-08 10:50 AM

<u>Analyses</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Guideline<sup>1</sup></u>
Coliforms, Total	less than 1	CFU/100mL	1	MAC: none detected
Verified E.coli	less than 1	CFU/100mL	1	MAC: none detected

### Glossary of Terms

<b>&lt;</b>	Less than the Reportable Detection Limit, except under circumstances where the detection limit is higher due to interferences, insufficient sample volume, or dilutions
<b>APHA</b>	American Public Health Association
<b>CFU/mL</b>	Colony Forming Units per 1 milliliter
<b>CFU/100mL</b>	Colony Forming Units per 100 milliliters
<b>Matrix</b>	SW = Surface water, TW = Treated water, DW = Distribution water, UGW = Untreated Ground water, RW = Raw water
<b>RDL</b>	Reportable Detection Limit

### References

1. Health Canada (2017). Guidelines for Canadian Drinking Water Quality—Summary Table. Water and Air Quality Bureau, Healthy Environments and Consumer Safety Branch, Health Canada, Ottawa, Ontario.