

ANALYTICAL RESULTS

Sample ID	8505 Outlook Rd			Sample #	1	
Date/Time Sampled	5/12/2020	11:00 AM	Matrix	UGW	Temperature on Receipt	14

Date/Time on Test 5/13/2020 12:25 PM

<u>Analyses</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Guideline¹</u>
Coliforms, Total	less than 1	CFU/100mL	1	MAC: none detected
Verified E.coli	less than 1	CFU/100mL	1	MAC: none detected

Sample ID	4515 Canning Rd			Sample #	2	
Date/Time Sampled	5/12/2020	11:30 AM	Matrix	UGW	Temperature on Receipt	13

Date/Time on Test 5/13/2020 12:30 PM

<u>Analyses</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Guideline¹</u>
Coliforms, Total	less than 1	CFU/100mL	1	MAC: none detected
Verified E.coli	less than 1	CFU/100mL	1	MAC: none detected

Glossary of Terms

Less than 1	Less than the Reportable Detection Limit, except under circumstances where the detection limit is higher due to interferences, insufficient sample volume, or dilutions.
APHA	American Public Health Association
CFU/mL	Colony Forming Units per 1 milliliter
CFU/100mL	Colony Forming Units per 100 milliliters
Matrix	SW = Surface water, TW = Treated water, DW = Distribution water, UGW = Untreated Ground water, RW = Raw water
RDL	Reportable Detection Limit

References

1. Health Canada (2017). Guidelines for Canadian Drinking Water Quality—Summary Table. Water and Air Quality Bureau, Healthy Environments and Consumer Safety Branch, Health Canada, Ottawa, Ontario.