

ANALYTICAL RESULTS

Sample ID	8505 Outlook Rd			Sample #	1	
Date/Time Sampled	8/24/2021	11:00 AM	Matrix	UGW	Temperature on Receipt	19
Date/Time on Test	8/25/2021	2:50 PM				
<u>Analyses</u>		<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Guideline¹</u>	
Coliforms, Total		Less than 1	CFU/100mL	1	MAC: none detected	
Verified E.coli		Less than 1	CFU/100mL	1	MAC: none detected	
Fecal (Thermotolerant) Coliforms		Less than 1	CFU/100mL	1	MAC: none detected	

Sample ID	4515 Canning Rd			Sample #	2	
Date/Time Sampled	8/24/2021	11:30 AM	Matrix	UGW	Temperature on Receipt	18
Date/Time on Test	8/25/2021	2:50 PM				
<u>Analyses</u>		<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Guideline¹</u>	
Coliforms, Total		Less than 1	CFU/100mL	1	MAC: none detected	
Verified E.coli		Less than 1	CFU/100mL	1	MAC: none detected	
Fecal (Thermotolerant) Coliforms		Less than 1	CFU/100mL	1	MAC: none detected	

Glossary of Terms

Less than 1	Less than the Reportable Detection Limit, except under circumstances where the detection limit is higher due to interferences, insufficient sample volume, or dilutions.
APHA	American Public Health Association
CFU/mL	Colony Forming Units per 1 milliliter
CFU/100mL	Colony Forming Units per 100 milliliters
Matrix	SW = Surface water, TW = Treated water, DW = Distribution water, UGW = Untreated Ground water, RW = Raw water
RDL	Reportable Detection Limit

References

1. Health Canada (2017). Guidelines for Canadian Drinking Water Quality—Summary Table. Water and Air Quality Bureau, Healthy Environments and Consumer Safety Branch, Health Canada, Ottawa, Ontario.