

**ANALYTICAL RESULTS**

Sample ID	6140 Community Centre Rd			Sample #	1	
Date/Time Sampled	2/8/2022	11:00 AM	Matrix	UGW	Temperature on Receipt	14

Date/Time on Test 2/9/2022 2:00 PM

<u>Analyses</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Guideline<sup>1</sup></u>
Coliforms, Total	Less than 1	CFU/100mL	1	MAC: none detected
Verified E.coli	Less than 1	CFU/100mL	1	MAC: none detected

Sample ID	3185 Ward Rd			Sample #	2	
Date/Time Sampled	2/8/2022	11:30 AM	Matrix	UGW	Temperature on Receipt	14

Date/Time on Test 2/9/2022 2:05 PM

<u>Analyses</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Guideline<sup>1</sup></u>
Coliforms, Total	Less than 1	CFU/100mL	1	MAC: none detected
Verified E.coli	Less than 1	CFU/100mL	1	MAC: none detected

**Glossary of Terms**

Less than 1	Less than the Reportable Detection Limit, except under circumstances where the detection limit is higher due to interferences, insufficient sample volume, or dilutions.
APHA	American Public Health Association
CFU/mL	Colony Forming Units per 1 milliliter
CFU/100mL	Colony Forming Units per 100 milliliters
Matrix	SW = Surface water, TW = Treated water, DW = Distribution water, UGW = Untreated Ground water, RW = Raw water
RDL	Reportable Detection Limit

**References**

1. Health Canada (2017). Guidelines for Canadian Drinking Water Quality—Summary Table. Water and Air Quality Bureau, Healthy Environments and Consumer Safety Branch, Health Canada, Ottawa, Ontario.