

ANALYTICAL RESULTS

Sample ID	6140 Community Centre Rd			Sample #	1	
Date/Time Sampled	2022-04-26	11:00 AM	Matrix	UGW	Temperature on Receipt	11

Date/Time on Test 2022-04-27 2:55 PM

<u>Analyses</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Guideline¹</u>
Coliforms, Total	less than 1	CFU/100mL	1	MAC: none detected
Verified E.coli	less than 1	CFU/100mL	1	MAC: none detected

Sample ID	3185 Hardy Mt. Rd.			Sample #	2	
Date/Time Sampled	2022-04-26	11:30 AM	Matrix	UGW	Temperature on Receipt	11

Date/Time on Test 2022-04-27 2:55 PM

<u>Analyses</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Guideline¹</u>
Coliforms, Total	less than 1	CFU/100mL	1	MAC: none detected
Verified E.coli	less than 1	CFU/100mL	1	MAC: none detected

Glossary of Terms

Less than 1	Less than the Reportable Detection Limit, except under circumstances where the detection limit is higher due to interferences, insufficient sample volume, or dilutions.
APHA	American Public Health Association
CFU/mL	Colony Forming Units per 1 milliliter
CFU/100mL	Colony Forming Units per 100 milliliters
Matrix	SW = Surface water, TW = Treated water, DW = Distribution water, UGW = Untreated Ground water, RW = Raw water
RDL	Reportable Detection Limit

References

1. Health Canada (2017). Guidelines for Canadian Drinking Water Quality—Summary Table. Water and Air Quality Bureau, Healthy Environments and Consumer Safety Branch, Health Canada, Ottawa, Ontario.