



TEST RESULTS

REPORTED TO PROJECT SION Improvement District
Drinking Water

WORK ORDER REPORTED 8011005
2018-01-17 16:27

Analyte	Result	Guideline	RL	Units	Analyzed	Qualifier
---------	--------	-----------	----	-------	----------	-----------

6140 Community Centre Road (8011005-01) | Matrix: Water | Sampled: 2018-01-15 11:30

Microbiological Parameters

Coliforms, Total	1	MAC = 0	1	CFU/100 mL	2018-01-16	
E. coli	< 1	MAC = 0	1	CFU/100 mL	2018-01-16	

3185 Ward Road (8011005-02) | Matrix: Water | Sampled: 2018-01-15 12:00

Microbiological Parameters

Coliforms, Total	< 1	MAC = 0	1	CFU/100 mL	2018-01-16	
E. coli	< 1	MAC = 0	1	CFU/100 mL	2018-01-16	